

## Certificate of Product Approval

Certificate Number: 1607c

Issue: 01

### Fort Engineering Limited

Unit E  
Bramingham Business Park  
Enterprise Way  
Luton  
Bedfordshire  
LU3 4BU

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

#### Product

##### **FORT003 LP3S**

hinged security doorsets

#### Standard

##### **LPS 1175: Issue 8**

Requirements and testing procedures for the LPCB certification and listing of intruder resistant building components, strongpoints, security enclosures and free-standing barriers

This certificate and appendix is maintained and held in force through regular surveillance activities



Signed for BRE Global Ltd.

Paul Dillon  
Verifier

15 March 2021  
Date of Issue

15 March 2021  
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



## Appendix to Certificate No: 1607c Fort Engineering Limited

Issue: 01

### Hinged Security Doorsets

Product Name	Type	Minimum Structural Opening Height (m)	Maximum Structural Opening Height (m)	Minimum Structural Opening Width (m)	Maximum Structural Opening Width (m)	Security Rating	LPCB Ref. No.
FORT003 LP3S	Single leaf, inward opening hinged doorset	1.7	2.5	0.65	1.3	C5 (SR3)	1607c/01

### Compatible Locking Systems

Manufacturer	Model	Type	Compatible Operating Devices		Compatible External Cylinders
			External Face	Internal Face	
ISEO	FIAM 678G	Three-point morticed locking system	Key and lever handle	Key and lever handle	ISEO R6 Plus

### Approved Accessories

Accessory	Description
Door viewer	Door viewer incorporated in the door leaf

### Notes:

- The security ratings apply to doorsets with locking fully engaged, i.e. in optimum locked condition. The doorsets achieve at least a Security Rating A1 classification when the locking systems are fitted and left in the minimum locked condition, e.g. when the door leaf was closed, cylinder thrown once, and key removed.
- Certification does not cover the use of locks or optional design features / accessories other than those listed. Utilisation of unlisted locks/options may affect the level of security afforded by the doorset.
- The doorsets are approved for installation in accordance with the instructions contained in the document titled 'Door Installation and Maintenance Instructions – FORT003 LP3S' (Version 2, dated 11 March 2021).

This certificate and appendix is maintained and held in force through regular surveillance activities



Signed for BRE Global Ltd.

Paul Dillon  
Verifier

15 March 2021  
Date of Issue

15 March 2021  
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.


