

Certificate of Product Approval

Certificate Number: 1450a

Issue: 09

Yingkou Tiancheng Fire Protection Equipment Co., Ltd

No. 11-2, Kechechang Xili
Xishi District, Yingkou,
Pilot Free Trade Zone (Liaoning)
115004
China



is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Alarm Warning Devices

TCSG5266

TCDZ517S

TCSG5270

(Refer to Appendix for details)

Standards

EN 54-3:2014 + A1: 2019

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd

Verifier

25 October 2023

Date of Issue

4 July 2019

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 1450a

Issue: 09

Yingkou Tiancheng Fire Protection Equipment Co., Ltd

Certified Product	Description	LPCB Ref.No.
TCSG5266	Addressable Sounder Strobe Type A (Base with 86H50 Embedded Box) Notes: Meets the requirements of EN 54-3: for the following tone 1) One Default Tone 3.5s ~ 4.5s The Beacon function is not approved to EN 54-23	1450a/01
TCDZ517S	Sounder Base Type A Notes: Meets the requirements of EN 54-3: for the following tones Tone 1, 1.67KHz-5.9KHz (3.5s - 4.5s) Tone 2, 2.85KHz-4.1KHz (0.1s - 0.4s)	1450a/02
TCSG5270	Addressable Sounder Strobe Type A Notes: Meets the requirements of EN 54-3: for the following tone 1) One Default Tone, 1.67KHz – 5.9KHz (3.5s - 4.5s) The Beacon function is not approved to EN 54-23	1450a/03

Base

Base with 86H50 Embedded Box

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

Z Major

Verifier

25 October 2023

Date of Issue

4 July 2019

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.


